



# Lauderhill

FIRE RESCUE

1980 NW 56 AVE • Lauderhill, Florida 33313  
Phone 954-730-2950 • Fax 954-730-2955

08/20/18

Universal Scrap Mgt

1157 NW 31ST AVE, #A  
Lauderhill, FL 33311

Inspection # 87573      Inspection Type Inspection Request  
Property # 8000429      Occupancy Type Industrial

## Flammables (M)

Ordinance Inspection	Compliance	Due Date
1:66.9.3.1 Improper storage of flammables	The general requirements of this chapter shall be applicable to the storage of liquids in liquid storage areas as covered in Chapters 10 through 14 of NFPA 30, regardless of the quantities being stored. Exception: Where more stringent requirements are set forth in Chapters 10 through 14 of NFPA 30, those requirements shall take precedence. [30:9.3.1]	09/03/18
Remark: Oxygen, propane and acetylene tanks must be properly chained to dolly or secured. Improper hot work	Provide 35ft clearance around hot work. Water, class D extinguisher and ABC extinguishers required during hot work operations.	09/03/18
Remark: Hot work was found being done without proper fire separation or fire protection		

## Inspection History

Inspection Date	Status	Inspected By
08/20/18	Violations Found	Inspector Newman

Inspector Newman

Property Remarks		
Category	Value	
AED		
Fire Alarm		
Fire Extinguisher	1/18	
Fire Sprinkler/Standpipe		
Hood		
K-Extinguisher		
Knox Box		
Occupant Load		

FAILURE TO COMPLY WILL RESULT IN THE ISSUANCE OF NOTICE TO APPEAR IN BROWARD COUNTY COURT OR UNIFORM CODE CITATION.

SIGNATURE OF RECIPIENT, BY SIGNING THIS REPORT I AM ADMITTING NO GUILT FOR THE VIOLATIONS CITED ABOVE, BUT SIMPLY ACKNOWLEDGE HAVING RECEIVED A COPY OF THIS REPORT.

ABOVE VIOLATIONS MAY CAUSE A FIRE, CONTRIBUTE TO THE SPREAD OF FIRE, OR CAUSE UNDUE INJURY TO BUILDING OCCUPANTS. VIOLATIONS MUST BE CORRECTED FORTHWITH.  
FOR ADDITIONAL INFORMATION CALL (954) 730-2950







