



Lauderhill

FIRE RESCUE

1980 NW 56 AVE • Lauderhill, Florida 33313
Phone 954-730-2950 • Fax 954-730-2955

6/3/2019

Universal Scrap Mgt

1157 NW 31ST AVE, #A
Lauderhill, FL 33311

Inspection # 90994 Inspection Type Annual (Requires Reinspection)
Property # 8000429 Occupancy Type Industrial

Flammables (M)

Ordinance	Inspection	Compliance	Due Date
	Submit Hot Work Permit		05/08/19

Hazardous Materials (N)

Ordinance	Inspection	Compliance	Due Date
1:60.5.1.8.2 .1	Warning Placard Signs Required	NFPA 704 Placard. Visible hazard identification signs in accordance with NFPA 704, Standard System for the Identification of the Hazards of Materials for Emergency Response, shall be placed at the following locations, except where the AHJ has received a hazardous materials management plan and a hazardous materials inventory statement that omission of such signs is consistent with safety: (1-4) [400:6.1.8.2.1]	04/24/19

Inspection History

Inspection Date	Status	Inspected By
4/10/2019	Violations Found	Inspector Newman
6/3/2019	Violations Found	Inspector Newman

Property Remarks

Category	Value
AED	
Fire Alarm	
Fire Extinguisher	1/19
Fire Sprinkler/Standpipe	
Hood	
K-Extinguisher	
Knox Box	
Occupant Load	

Inspection Remarks

Please resubmit hot work permit for 6 month approval.

Install 704 placard for gasoline.

Conex boxes still remain above single story height. Must be lowered.

++ advised that electrical plan is in works and upon submittal conex boxes will be lowered.

Debris piles must be maintained no higher than 20 ft at any time.

Customer

Emailed

Inspector Newman

FAILURE TO COMPLY WILL RESULT IN THE ISSUANCE OF NOTICE TO APPEAR IN BROWARD COUNTY COURT OR UNIFORM CODE CITATION.

SIGNATURE OF RECIPIENT, BY SIGNING THIS REPORT I AM ADMITTING NO GUILT FOR THE VIOLATIONS CITED ABOVE, BUT SIMPLY ACKNOWLEDGE HAVING RECEIVED A COPY OF THIS REPORT.

ABOVE VIOLATIONS MAY CAUSE A FIRE, CONTRIBUTE TO THE SPREAD OF FIRE, OR CAUSE UNDUE INJURY TO BUILDING OCCUPANTS. VIOLATIONS MUST BE CORRECTED FORTHWITH.
FOR ADDITIONAL INFORMATION CALL (954) 730-2950

