



# Lauderhill

FIRE RESCUE

1980 NW 56 AVE • Lauderhill, Florida 33313  
Phone 954-730-2950 • Fax 954-730-2955

9/20/2018

Universal Scrap Mgt

1157 NW 31ST AVE, #A

Lauderhill, FL 33311

---

Inspection #	88261	Inspection Type	Inspection Request
Property #	8000429	Occupancy Type	Industrial

---

### Notes (0)

Ordinance Inspection	Compliance	Due Date
See Narrative		10/04/18

---

## Inspection History

Inspection Date	Status	Inspected By
9/20/2018	Violations Found	Inspector Newman

Property Remarks	
Category	Value
AED	
Fire Alarm	
Fire Extinguisher	1/18
Fire Sprinkler/Standpipe	
Hood	
K-Extinguisher	
Knox Box	
Occupant Load	

### Inspection Remarks

Property is hereby ordered to Cease and Desist all mechanized operations of shredding and compacting of materials.

The power source to all mechanical units must be removed within 72 hours. A permit will be required for any power supply to conex boxes.

Property must meet compliance of FS633.025 and City Ordinance 9-2 and Florida Fire Prevention Code, NFPA 1.

All flammable and hazardous materials must be removed from property.

Conex boxes must be lowered to one level.

Debris piles must be moved 300 feet from property line and kept to a height of 20 ft.

FD access roads will need to be created and maintained at all times.

Annual Hot Permits will be required for all hot work.

No burning operations are permitted.

No tires are to be stored on property.

Retention barriers will be needed to mitigate spillage.

Customer

A handwritten signature consisting of a large, stylized loop on the left and a long horizontal line extending to the right.

Inspector Newman

FAILURE TO COMPLY WILL RESULT IN THE ISSUANCE OF NOTICE TO APPEAR IN BROWARD COUNTY COURT OR UNIFORM CODE CITATION.

SIGNATURE OF RECIPIENT, BY SIGNING THIS REPORT I AM ADMITTING NO GUILT FOR THE VIOLATIONS CITED ABOVE, BUT SIMPLY ACKNOWLEDGE HAVING RECEIVED A COPY OF THIS REPORT.

ABOVE VIOLATIONS MAY CAUSE A FIRE, CONTRIBURE TO THE SPREAD OF FIRE, OR CAUSE UNDUE INJURY TO BUILDING OCCUPANTS. VIOLATIONS MUST BE CORRECTED FORTHWITH.  
FOR ADDITIONAL INFORMATION CALL (954) 730-2950