



Lauderhill

FIRE RESCUE

1980 NW 56 AVE • Lauderhill, Florida 33313
Phone 954-730-2950 • Fax 954-730-2955

08/01/18

Universal Scrap Mgt

1157 NW 31ST AVE, #A

Lauderhill, FL 33311

Inspection #	86805	Inspection Type	Annual (Requires Reinspection)
Property #	8000429	Occupancy Type	Industrial

Fire Protection (J)

Ordinance Inspection	Compliance	Due Date
Install Class D extinguish		08/15/18

Remark: Class D extinguisher needed due to storage of class D combustibles.

Flammables (M)

Ordinance Inspection	Compliance	Due Date
1:66.9.3.1 Improper storage of flammables	The general requirements of this chapter shall be applicable to the storage of liquids in liquid storage areas as covered in Chapters 10 through 14 of NFPA 30, regardless of the quantities being stored. Exception: Where more stringent requirements are set forth in Chapters 10 through 14 of NFPA 30, those requirements shall take precedence. [30:9.3.1]	08/15/18

Remark: High piling of combustibles is not permitted.