



(561) 640-3503 - Phone

Hinterland Group, Inc.
2051 W Blue Heron Blvd
Riviera Beach, FL 33404

ALL PO's/Contractual Issuances are to be emailed to: info@hinterlandgroup.com

Proposal # 18-0268-09

ADDRESS
City of Lauderhill
Bob Snyder

DATE: 10/21/2019

JOB NAME: Lift Station #53 - Base Plates Only

ACTIVITY	QUANTITY	UNIT	RATE	AMOUNT
Furnish and Install Base Plates at LS #53 - 1/2" Thick A36 Steel plates	2	EA	\$800.00	\$1,600.00
TOTAL			\$	1,600.00

Notes:

1. Vactor provided by city
2. Work to be performed in conjunction with proposal 18-0268-06

ALL PO's/Contractual Issuances are to be emailed to: info@hinterlandgroup.com

Accepted By:

Accepted Date:

10/31/19



Hinterland Group, Inc.
 2051 W Blue Heron Blvd
 Riviera Beach, FL 33404

(561) 640-3503 - Phone

ALL PO's/Contractual Issuances are to be emailed to: info@hinterlandgroup.com

Invoice # 18-0268-05F

ADDRESS
 City of Lauderhill
 Bob Snyder

DATE: 10/15/2019

JOB NAME: Lift Station #44 - Emergency Bypass and Valve Replacement

ACTIVITY	QUANTITY	UNIT	RATE	AMOUNT
Line Item #52 - Bypass pumping - 6"	2	WK	\$5,000.00	\$10,000.00

TOTAL \$ 10,000.00

- Notes:
 1. Vactor provided by city
 2. No 4" valves in contract, using 6" pricing

Approved:

City of Lauderhill



Right-click to print
with CoSign

EMERGENCY PURCHASE APPROVAL FORM Revised

Today's Date 10/30/19

Emergency Date: 9/19/19

Department:

Utilities

Item(s) Needed:

Bypass pump rental and repair of lift station #44 which includes installing new suction, discharge valve, and check valves.

Bypass pump, replacement of Guide rails, and pump bases at lift station #53

Reason for Need:

On Thursday, September 19, 2019, and early Friday morning, September 20, 2019 Utilities experienced an issue with lift station 53 and Lift station 44 which serves the Cascades/Northwest Communities. As staff worked to assess the situation with both systems the following was determined. At lift station 53 the "T" guide rails system that support the pumps had detached from the wet well of the lift station. This caused the pumps to malfunction and not operate at capacity. Consequently, a temporary by pass pumping system had to be placed at this location until permanent repairs can be made.

At Lift Station 44 staff attempted to isolate valve to the pumps inside the lift station. As staff attempted to isolate the pumps with the valves, to stop the flow of sewer to remove the pump. It was determined that isolating the valve to repair the pump was the issue. Consequently, we had to place a temporary by pass pumping system at this location until permanent repairs can be made.

Vendor: Hinterland Group

Estimated Cost: Approximate cost for repairs to Lift Station 53 is \$38,000.00 Approximate cost for repairs to Lift Station 44 is \$20,000. Additional expense in the amount of \$11,600.00 for by pass pumping due to the time frame of manufacturing the two new guide rail systems and base plates.


Herb Johnson
Oct 30 2019 4:21 PM 

Date: _____

Department Director

Approved

Disapproved


Kennie Hobbs
Oct 30 2019 5:29 PM 



Date: 10-31-19

City Manager or Designee

This form is to be used only for emergency purchases and services needed immediately. The reason for the immediate need must be documented and approved by the City Manager or Assistant City Manager prior to the purchase or service being procured. Emergency purchases are generally needed when the health, safety or welfare of the citizens is in jeopardy. If emergencies arise during hours in which City Hall is closed and purchases or services must be acquired, an e-mail must be sent and approved by the City Manager or Assistant City Manager first, then this form must be filled out completely and turned in for approval on the next business day that is available. **DEPARTMENT DIRECTOR WILL BE HELD RESPONSIBLE FOR SUCH PURCHASES.**