



Lauderhill

FIRE RESCUE

1980 NW 56 AVE • Lauderhill, Florida 33313
Phone 954-730-2950 • Fax 954-730-2955

8/21/2019

Universal Scrap Mgt

1157 NW 31ST AVE, #A
Lauderhill, FL 33311

Inspection # 93295 Inspection Type Inspection Request
Property # 8000429 Occupancy Type Industrial

General (H)

Ordinance	Inspection	Compliance	Due Date
1:10.18.3.1	Improper Height - storage	Storage shall be maintained 2ft or more from the ceiling in nonsprinklered areas of buildings	09/04/19

Inspection History

Inspection Date	Status	Inspected By
8/21/2019	Violations Found	Inspector Newman

Property Remarks

Category	Value
AED	
Fire Alarm	
Fire Extinguisher	1/19
Fire Sprinkler/Standpipe	
Hood	
K-Extinguisher	
Knox Box	
Occupant Load	

Inspection Remarks

Responded to location due to Lauderhill Code Enforcement receiving complaints from Larkdale Elementary School Staff stating the location was burning something and smoke was causing students respiratory distress (LFD Incident #1108811). Upon arrival no burning or hot work was noted, however, large piles of debris were found in excess of height and size limitations (see attached photos)

Customer

For File

Inspector Newman

FAILURE TO COMPLY WILL RESULT IN THE ISSUANCE OF NOTICE TO APPEAR IN BROWARD COUNTY COURT OR UNIFORM CODE CITATION.

SIGNATURE OF RECIPIENT, BY SIGNING THIS REPORT I AM ADMITTING NO GUILT FOR THE VIOLATIONS CITED ABOVE, BUT SIMPLY ACKNOWLEDGE HAVING RECEIVED A COPY OF THIS REPORT.

**ABOVE VIOLATIONS MAY CAUSE A FIRE, CONTRIBUTE TO THE SPREAD OF FIRE, OR CAUSE UNDUE INJURY TO BUILDING OCCUPANTS. VIOLATIONS MUST BE CORRECTED FORTHWITH.
FOR ADDITIONAL INFORMATION CALL (954) 730-2950**

Attachments

Improper Height - storage

8/21/2019



Improper Height - storage

8/21/2019

