



TABLE 1-1. MINIMUM SPACE REQUIREMENTS AT VARIOUS PARKING ANGLES FOR SELF-PARKING FACILITIES

Parking Pattern Degrees	Aisle Width (feet)	Parking Space Width (feet)	Parking Space Length (feet)
0 (Parallel Parking)	12*	9	23
20-50	15*	9	18
60	18*	9	18
70	20*	9	18
75	22*	9	18
80	24*	9	18
90	24	9	18

1.3.22. Retail stores, personal service shops, household repair or equipment shops: One (1) parking space for every two hundred (200) square feet of gross floor area.

1.3.19. Restaurants, fast-food restaurants, lounges, bars, nightclubs; if part of a shopping center: One (1) parking space for every fifty (50) square feet of customer-service floor area and one (1) parking space for every two hundred (200) square feet of all other area. All restaurants, fast-food restaurants, lounges, bars and nightclubs which are not part of a shopping center: One (1) parking space for every thirty (30) square feet of floor area in rooms for customer service, including customer waiting area.

Site Plan Received on 10/15/2020

- The 10th queue vehicle is on the ADA crosswalk.
- The 11th queue vehicle blocks the east-west internal road.
- The proposed Popeyes is larger than the site used for the queue data and therefore higher traffic and longer queues. The maximum queue of 8 would increase to 11. Thus, 11 queue spaces are needed.

Provided: 56 parking spaces

