



1
A-1 PROPOSED SITE PLAN
ICE LAUDERDALE FACILITY
1/16"=1'-0"

SECURITY FENCE NOTES

1. THE FENCE LINE REFLECTED ON ARCHITECTURAL DRAWINGS IS FOR GRAPHIC REPRESENTATION PURPOSES ONLY.
2. THE FENCE CONTRACTOR IS RESPONSIBLE TO PREPARATION OF ENGINEERED DRAWINGS AS WELL AS TO SECURE ALL REQUIRED PERMITS FOR THE ENTIRE FENCE PROJECT.
3. FENCE CONTRACTORS IS TO SHOP-DRAWINGS FOR ARCHITECTS AND CLIENT REVIEW PRIOR TO THE PURCHASE AND INSTALLATION OF ANY AND ALL EQUIPMENT.

SECURITY CONTRACTOR NOTES

1. GC TO COORDINATE & PROVIDE THE NECESSARY POINT OF CONNECTION (POWDER AND/OR LOW VOLTAGE) FOR HATCH ACCESS SELECTED/SPECIFIED DEVICE BY THE SECURITY CONSULTANT.
2. THE SECURITY CONSULTANT IS TO PROVIDE SHOP-DRAWINGS AND REQUIRED SUB-PERMITS FOR THE ENTIRE SECURITY CONTROL SYSTEM PRIOR TO PURCHASE AND INSTALLATION OF ANY AND ALL EQUIPMENT.

GENERAL CONTRACTOR NOTES

1. G.C. TO PROVIDE AND COORDINATE ALL MATERIALS AND LABOR FOR THE RETROFITTING OF THE EXISTING ROLLUP GATE OPENING MECHANISM FROM MANUAL TO MOTORIZED.
2. GENERAL CONTRACTOR TO SHOP-DRAWINGS FOR ARCHITECTS AND CLIENT REVIEW PRIOR TO THE PURCHASE AND INSTALLATION OF ANY AND ALL EQUIPMENT.

VEHICULAR GATES NOTE

GC TO PROVIDE "CLICK 2" SYSTEM TO ALL EXISTING & NEW AUTOMATIC GATES AS REQUIRED FROM THE FIRE PROTECTION CODE, F-108.9.3 STATES THAT "ALL NEW AND EXISTING AUTOMATIC ENTRY GATES INSTALLED IN EITHER COMMERCIAL OR MULTIFAMILY COMMUNITIES SHALL BE PROVIDED WITH UNIVERSAL ACCESS SYSTEM, APPROVED BY THE FIRE PREVENTION SUBCOMMITTEE OF THE FIRE CHIEFS ASSOCIATION OF BROWARD COUNTY, TO ALLOW RAPID ENTRY. EXISTING APPLICATIONS MAY BE PROVIDED UP TO ONE(1) YEAR TO COMPLETE AS APPROVED BY THE AHJ".

SECURITY ELEMENTS LEGEND & NOTES

	SECURITY CAMERAS
	CARD READER

ALL SECURITY DEVICES SHOWN ARE FOR REPRESENTATION AND LOCATION PURPOSES ONLY. REFER TO THE SECURITY CONSULTANT DRAWINGS AND SPECIFICATIONS FOR PERMITTING AND THEIR IMPLEMENTATION INTO THE PROJECT.

LIGHT FIXTURE SPECIFICATIONS

LIGHT FIXT.	TAG	QTY.	ARRANGEMENT	MANUF.	MODEL NUMBER	MOUNTING	LFF	LUMINAIRE LUMENS	LUMINAIRE WATTS	ARRNG. WATTS
	A	2	SINGLE	STERNBERG	PT8-SL360-FG-26L45-15-MDLO 7-PEC-UBT	BOLLARD	0.855	5348	61.9	61.9
	B	5	SINGLE	LTHONIA LIGHTING	WDGE2 LED P4 40K 80CRI T4M	22' WALL MOUNT A.F.F. (Bottom of fixture)	0.855	4177	46.6589	46.659
	C	3	SINGLE	LTHONIA LIGHTING	DSX1 LED P9 40K 80CRI T5W	20' POLE MOUNT A.F.G.	0.855	33103	277.07	277.07
	E	3	SINGLE	LTHONIA LIGHTING	NDSX1 LED P7 40K 80CRI BLC4	20' POLE MOUNT A.F.G.	0.855	15306	184.43	184.43
	F	8	SINGLE	LTHONIA LIGHTING	DSX1 LED P5 40K 80CRI BLC3	14' POLE MOUNT A.F.G.	0.855	11764	138.16	138.16

PARKING STRIPPING NOTE

ALL EXISTING PARKING STRIPPING TO BE RESTRIPTED TO MATCH EXISTING U.O.N.

REVISIONS

NO.	DESCRIPTION